

ADDENDUM NO. 2 TO BID FORMS

CORONA-NORCO UNIFIED SCHOOL DISTRICT PURCHASING DEPARTMENT Bid No. 2023/24-210 TRANSPORTATION OFFICE EXPANSION

The following changes, additions, deletions, or corrections shall become part of this solicitation and the contract documents for the Bid named above.

RESPONSE TO BIDDING CONTRACTOR'S QUESTION

Question No. 1: Sheet T1.01 detail 1 shows the technology connection point in the IDF room connected to building G. Can you confirm this is correct?

Answer No. 1: Please see the revised sheet T1.01 showing the connection to the MDF.

Question No. 2: Is this project subject to Skilled & Trained Workforce requirements? If so, what are the requirements?

Answer No. 2: No, this project is not subject to Skilled and Trained Workforce Requirements.

Question No. 3: In the bidder prequalification package it states: Provide the name, address and telephone number of the apprenticeship program sponsor(s) that will provide skilled journeypersons or apprentices as part of the "Skilled and Trained Workforce" to your firm as required by Education Code section 17407.5(b)(3) for use on any public works project for which you are awarded a contract by Corona-Norco Unified School District.

Answer No. 3: In section 8 of the prequalification package, the name of apprenticeship program is requested if available.

Question No. 4: In the Invitation for Bids there is no mention of a Skilled and Trained Workforce requirement. Therefore, is a Skilled and Trained Workforce required for this project? And, If so, it is required of ALL subcontractors or just subcontractors who require prequalification (I.e. MEP subcontractors).

Answer No. 4: No, please refer to question/answer no.2.

Question No. 5: The sign-in sheet is available to view in the public documents.

Answer No. 5: Yes, the document is available on the District's website and BonFire.

END OF ADDENDUM NO. 2

BELOW, PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM NO. 1 AND SUBMIT WITH YOUR BID OR BE DEEMED NONRESPONSIVE.

Signature: _____

Print Name and Title: _____

Firm Name: _____

Address: _____

Telephone Number: _____

Email Address: _____

- ◇ AREA OF WORK.
- ◇ INDICATES APPROXIMATE LOCATION OF EXISTING MDF FLOOR STANDING RACK.
- ◇ INDICATES LOCATION OF NEW IDF WALL MOUNTED CABINET COPY ROOM.
- ◇ 36"X36"X36" CONCRETE PULL BOX INSTALLED FLUSH WITH GRADE FOR TELECOM SYSTEMS. PROVIDE EVERY 250' OR CHANGES OF DIRECTION MORE THAN 180 DEGREES. PROVIDE WIDE SWEEPING TURNS ON ALL CONDUIT ENTERING AND EXITING BOX AS WELL AS ALL CONDUIT TURNS ALONG ROUTE. PULL BOX SHALL BE RATED FOR THE TERRAIN IN WHICH IT SHALL BE INSTALLED. DO NOT INSTALL PULL BOXES IN SIDEWALKS. PULL BOXES INSTALLED IN PARKING LOTS OR DRIVEWAYS MUST BE RATED FOR SUCH AN ENVIRONMENT. VERIFY PROPER LOCATION PRIOR TO INSTALLATION. TYPICAL FOR ALL LOCATIONS SHOWN.
- ◇ CONTRACTOR SHALL PROVIDE (2) 2" CONDUITS, EACH WITH (2) 2-CELL MAXCELL INNERDUCT. CONTRACTOR SHALL ROUTE (1) 6-STRAND SINGLE MODE FIBER UNDERGROUND TO NEW WALL MOUNTED IDF CABINET.
- ◇ INDICATES APPROXIMATE FIBER PATHWAY FOM EXISTING MDF TO NEW IDF WALL MOUNTED CABINET, 6 STRANDS S.M.F TO BE PROVIDED.
- ◇ CONTRACTOR SHALL BORE (2) 2" CONDUITS UNDERGROUND TO A NEMA 4 ENCLOSURE MOUNTED TO BUILDING EXTERIOR ABOVE CEILING HEIGHT.

NOTE:

FOR (E) GATES ALONG THE PATH OF TRAVEL ROUTE CONTRACTOR TO ADJUST DOOR OPENING FORCE TO COMPLY WITH CBC SECTION 11B-404.2.9 AND CLOSING SPEED TO COMPLY WITH SECTION 11B-404.2.8.

THE FORCE FOR PUSHING OR PULLING TO OPEN A DOOR OR GATE SHALL BE AS FOLLOWS:

1. INTERIOR HINGED DOORS AND GATES: 5 POUNDS MAXIMUM.
2. SLIDING OR FOLDING DOORS: 5 POUNDS MAXIMUM.
3. REQUIRED FIRE DOORS: THE MINIMUM OPENING FORCE ALLOWABLE BY THE APPROPRIATE ADMINISTRATIVE AUTHORITY, NOT TO EXCEED 15 POUNDS.
4. EXTERIOR HINGED DOORS: 5 POUNDS MAXIMUM.

THESE FORCES DO NOT APPLY TO THE FORCE REQUIRED TO RETRACT LATCH BOLTS OR DISENGAGE OTHER DEVICES THAT HOLD THE DOOR OR GATE IN A CLOSED POSITION.



ARCHITECT
 PBK Architects, Inc.
 RANCHO CUCAMONGA
 8163 Rochester Avenue, Suite 100
 Rancho Cucamonga
 California 91730
 P 909-987-0909


CONSULTANT
 LEAF Engineers




8163 Rochester Avenue, Suite 100
 Rancho Cucamonga, CA 91730
 909-987-0909
 leafengineers.com

CORONA TRANSPORTATION

PROJECT ADDRESS:
 2820 CLARK AVE
 NORCO, CA 92860
 DSA Submittal
 DSA APPL. NO. 04-121856 DSA FILE NO. 33-9



Consultant



CLIENT		
CORONA-NORCO USD	PROJECT NUMBER 230010	
DATE 05-19-03		
REVISIONS		
No.	Description	Date

DSA Submittal

TECHNOLOGY SITE PLAN